

**SCOPE OF WORK :AS 1530.8.1 (2018) TESTING ON EKODECK BAL**

Issue Date: 2019/03/12

**REPORT ISSUED TO**

**EKOLOGIX AUSTRALIA PTY LTD**

Unit 1 20-26 Sabre Drive  
Port Melbourne, Vic, 3207  
Australia

**Product Name:** Ekodeck BAL

**Decking Size:** 137 mm wide × 23 mm thick


**Bushfire attack level :** BAL: A29


The test was conducted in accordance with AS 1530.8.1:2018 Methods for fire tests on building materials, components and structures, Part 8.1: Tests on elements of construction for buildings exposed to simulated bushfire attack-Radiant heat and small flaming sources, Section 21 SPECIFIC PROCEDURES FOR DECKS.

The test method was modified as described below:

The depth of deck is 750 mm per AS 1530.8.1 and the depth of actual deck is 837 mm with one deck board width is 137 mm.

**More details,check the formal text report:190222007SHF-001**

<b>COMPLETED BY:</b>	Jason Xu
<b>TITLE:</b>	Project Engineer – Building & Construction
<b>SIGNATURE:</b>	
<b>DATE:</b>	2019/03/12

<b>REVIEWED BY:</b>	Harrison Li
<b>TITLE:</b>	Technical Supervisor – Building & Construction
<b>SIGNATURE:</b>	
<b>DATE:</b>	2019/03/12

