

## Test Report

### SCOPE OF WORK

WPC Co-extrusion Decking

### REPORT NUMBER

191218010SHF-001

### TEST DATE(S)


2019-12-18 - 2020-01-07

### ISSUE DATE

2020-01-07

Applicant: Ekologix Australia Pty Ltd

Address: Unit 1, 20-26 Sabre Drive, Port Melbourne, Victoria, Australia 3207



### Product Information

Product Name	WPC Co-extrusion Decking	Brand	Ekodeck
Sample Description	Good Condition	Sample Amount	8 pieces
		Received Date	2019-12-17
Sample ID	Model	Specification	
S191218010SHF.001	Designer Series/ Designer Series BAL 29	137x23mm	


### Test Items, Method and Results:

Test item	Test Method	Test result
Slip resistance (Oil-wet ramp test)	DIN 51130:2014	Angle: 18.6 ° Rating: R 10

### Appendix A: Sample Received Photo



### Report Authorized



Name: Flora Fan      Name: Milo Liu  
 Title: Reviewer      Title: Project Engineer