

## Test Report

Number: GZHH00352290

Applicant: EKOLOGIX AUSTRALIA PTY LTD  
UNIT 1, 20-26 SABRE DRIVE, PORT  
MELBOURNE VIC, AUSTRALIA 3207

Date: Jan 19, 2020

### Sample Description:

One (1) submitted sample said to be WPC Decking  
Product Name : Ekodeck & Ekodeck Plus  
Brand : Ekodeck  
Model : Ekodeck & Ekodeck Plus  
Country of Destination : China  
Country of Origin : China  
Date Sample Received : Jan 13, 2020  
Testing Period : Jan 13, 2020 to Jan 17, 2020



### Tests conducted:

As requested by the applicant, refer to attached page(s) for details.


### Conclusion:

Tested sample  
Submitted sample

Test Standard  
Slip resistance (oil – wet ramp test)  
As per DIN 51130: 2014-02 testing of floor coverings  
– Determination of the anti-slip property – Workrooms  
and fields of activities with slip danger, walking  
method -Ramp test

Result  
See test  
conducted

Authorized by:  
For Intertek Testing Services Shenzhen Ltd.  
Guangzhou Branch, Hardlines

  
Victor T.J. Wang  
Assistant General Manager



**Test Report**

Number: GZHH00352290

Tests Conducted

1 Slip Resistance (Oil – Wet Ramp Test)

As per the DIN 51130: 2014-02 testing of floor coverings – Determination of the anti-slip property – Workrooms and fields of activities with slip danger, walking method -Ramp test, the submitted sample was subjected to the following test:


Initial inspection: No any damage was found.

Sample size: 1005mm x 137mm x 23mm.

Executive summary:

Test item	Classification of oil-wet ramp test		Test result(s)	Classification
Slip resistance (oil – wet ramp test)	Classification	Angle (degress)	Critical angle of inclination: 21.0 °	R11
	R9	6°≤X≤10°		
	R10	10°≤X≤19°		
	R11	19°≤X≤27°		
	R12	27°≤X≤35°		
R13	X>35°			

**Photo for reference:**



\*\*\*\*\*

End of report

*The statements of conformity reported have considered the decision rule agreed, namely that Intertek have taken account of measurement uncertainty as calculated by Intertek, and applied according to ILAC-G8/09:2019 (APPENDIX B – Example 2) except designation from the customer, regulation or test specification.*

*This report is made solely on the basis of your instructions and/or information and materials supplied by you. It is not intended to be a recommendation for any particular course of action. Intertek does not accept a duty of care or any other responsibility to any person other than the Client in respect of this report and only accepts liability to the Client insofar as is expressly contained in the terms and conditions governing Intertek's provision of services to you. Intertek makes no warranties or representations either express or implied with respect to this report save as provided for in those terms and conditions. We have aimed to conduct the Review on a diligent and careful basis and we do not accept any liability to you for any loss arising out of or in connection with this report, in contract, tort, by statute or otherwise, except in the event of our gross negligence or wilful misconduct. This report shall not be reproduced unless with prior written approval from Intertek Testing Services Shenzhen Limited, Guangzhou Branch.*

